

Pathways and Ramps

Minimum Unobstructed Width 1000mm. Preferred Unobstructed Width 1200mm. The side slope of paths must be almost level. See ([Landings](#)). (These sizes do not include kerbs and handrails so an allowance needs to be made for these obstructions)

Ramps replacing a single stair must be an incline of 1:8, i.e. the horizontal length is 8 times the vertical rise, up to a maximum length of 1520mm. All other ramps must be a maximum slope of 1:14 and have a landing every 9 metres (Preferably every 6 Metres)

